

WATER SOFTENER PROJECT RFP 2019

County of Aroostook

4/1/2019

ADDENDUM #2

Materials D. #2 is amended to: two hundred eighty (280) gallons per hour or four and six tenths (4.6) gallons per minute peak flow;

And not: ~~two hundred eight (280) gallon per minute (gpm) peak flow;~~

Attest: Bryan Jandreau, Facilities & IT Director

A handwritten signature in blue ink, appearing to read "B. Jandreau". The signature is cursive and somewhat stylized, with a large initial "B" and a long, sweeping underline.